

TEST REPORT

| DATE: 12/03/2008 | TEST NUMBER: 117908 | |
|-----------------------|---|--|
| CLIENT | Superior Manufacturing Group - Moselle Division | |
| | | |
| TEST METHOD CONDUCTED | ASTM D1894-01 Modified Mat Slip Test | |

| DESCRIPTION OF TEST SAMPLE | | |
|----------------------------|----------------------------------|--|
| IDENTIFICATION | #413 Regular Dynashield Compound | |
| COLOR | Black | |
| ROLL | | |
| CONSTRUCTION | PVC Plastisol | |
| FIBER | Foam Product | |
| BACKING | | |
| REFERENCE | | |

GENERAL PRINCIPLE

This method is used to determine the slip resistance of a material while weighted with a static load. A 2'x3' sample was used with a 50 lbs static load. The test was conducted over painted concrete. Four pulls were made and reported as an average.

TEST RESULTS

| IDENTIFICATION | AVERAGE SKID RESISTANCE | AVERAGE COEFFICIENT OF FRICTION |
|------------------------|-------------------------|---------------------------------|
| VCT | 50.6 Lbs. | 1.02 |
| Painted Concrete | 51.6 Lbs. | 1.032 |
| Vinyl | 51.2 Lbs. | 1.024 |
| Epoxy Painted Concrete | 50.4 Lbs. | 1.006 |

APPROVED BY: Harry atluny

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical of similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.